

## First County Scaffolding

report prepared for

### **ABC Construction**

# Scaffold Inspection Report

All in accordance with the work at height regulations 2005 Schedule 7

#### Report Type:

Inspection Summary

**Contract Number:** 

0001

Site Name:

York Racecourse

Site Address:

York, Station Road, United Kingdom

Date:

6th October 2017 - 25th October 2017

	Scaffold	Location	Area	Inspect Type	tion Result	Identified risks to the health and safety of any person	Hazards reported to	Inspector's recommendations	Inspector	Date & time
♦	00001	Main Retail Complex	Default area	7	U	Putlogs and transoms:Some missing 3 missing on the second lift	Michael Glueck	none	John Doe	06/10/17 14:19
•	00002		Area 2	7	Nf	Footings:Soft and uneven Ground uneven and not stable	Michael Glueck 06/10/17	None	Richard Night	06/10/17 14:16
•	00003	Lower ground floor loc	Area 2	7	Nm	Footings:Undermined Due to trench dug by ground works for services	Michael Glueck 06/10/17	none	John Doe	06/10/17 14:17
•	00004	Upper void roof space	Area 2	7	Nm	Footings:Undermined Due to trench dug by ground works for services	Michael Glueck	none	John Doe	06/10/17 14:17

## Items checked during inspection

Footings	Couplings			
Soft and uneven	Wrong fitting			
Missing base plates	No check couplers			
Missing sole boards	Loose			
Undermined	Damaged			
Standards	Bridles			
Not plumb	Weak support			
Jointed at the same level	Wrong spacing			
Wrong spacing	Wrong couplers			
Damaged	Ties			
Ledgers	Some missing			
Loose	Loose			
Not level	Boarding			
Joint in same bays	Bad boards			
Damaged	Trap boards			
Bracing	Incomplete boarding			
Plan bracing missing	Insufficient supports			
Ledger bracing missing	Guard-rails and toe-boards			
Incorrect use of fittings	Loose			
Material Damage	Wrong height			
Putlogs and transoms	Some missing			
Incorrectly spaced	Ladders			
Some missing	Not tied			
Loose	Damaged			
Wrong fittings	Insufficient length			

## **Appendix**



00003:Footings:Undermined (06/10/17 14:17)



00001:Putlogs and transoms:Some missing (06/10/17 14:19)



00002:Footings:Soft and uneven (06/10/17 14:16)



00004:Footings:Undermined (06/10/17 14:17)